



Special Pathogens Laboratory

The Legionella Experts - Pittsburgh, PA

Account:

Date Reported: 1/2/2008

Special Pathogens Laboratory

1401 Forbes Avenue
Pittsburgh, PA 15219

ATTN: Janet Stout
Phone: (412) 281-5335

Fax: (412) 282-7445

Sample ID: 8-A- 4168 Type: Water
Taken From: Test Sample
Comments:

Date Collected: 12/31/2007
Date Received: 1/2/2008

Test: **Waterborne Pathogens Panel**

Legionella

Test Results: Positive
Identification: L. pneumophila, serogroup 6
Concentration: 10 CFU/ml
Test Comments:

Acinetobacter spp

Test Results: Negative
Identification: Not Applicable
Concentration: Not Applicable
Test Comments:

Pseudomonas aeruginosa

Test Results: Negative
Identification: Not Applicable
Concentration: Not Applicable
Test Comments:

Stenotrophomonas maltophilia

Test Results: Negative
Identification: Not Applicable
Concentration: Not Applicable
Test Comments:

- * Culture panel detects Legionella, Pseudomonas aeruginosa, Stenotrophomonas maltophilia, and Acinetobacter spp.
- * CFU/ml (or 100 ml) = Colony Forming Units per milliliter (or 100 ml) of sample.
- * Legionella culture limit of detection is approximately 10 CFU/ml. Potable water samples are filter concentrated, and the limit of detection is approximately 1 - 10 CFU/mL.
- * Uninterpretable - Culture overgrown by other bacteria.
- * Key to Abbreviations: CT- Cooling Tower; HWT - Hot Water Tank

Janet E. Stout, Ph.D.
Microbiologist
Director, Special Pathogens Laboratory